

Building 911A P.O. Box 5000 Upton, NY 11973-5000 Phone 631 344-7934 Fax 631 344-5676 piper@bnl.gov

managed by Brookhaven Science Associates for the U.S. Department of Energy

Memo

date: May 11, 2004

to: Distribution

from: A. Piper

subject: "Safety-Walk"

On Friday, May 7, 2004 at 10:00 hours, A "Safety-Walk" was Performed focusing on the Siemens watch building tour which is performed daily by this group.

Safety-Walk Attendees:

Arthur Piper (C-A ESHQ) David Passarello (C-A ESHQ) Chris Watts (Technician)

Task: Siemens watch building tour performed by the siemens MG operators

Positive Observations:

- Areas were posted as noise areas where applicable
- Ear plugs were available in posted noise areas
- PCB postings were in place where applicable
- A procedure and checklist are utilized to perform these daily "rounds"

Negative Observations:

- The basement of building 928 requires a survey to determine if it should be posted as a noise area requiring hearing protection
- The area on top of "room 242" located in the 928 basement requires additional barriers/postings indicating the electrical hazard in the buss work area toward the south end of the basement.

Distribution: Safety-Walk attendees R. Karol

E. Lessard

D. Lowenstein